



CB TEST CERTIFICATE

Ref. Certificate No.

NL-33683

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Air circuit-breaker		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok- gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3 and 4 pole ACB (Electronic trip unit) In = 4000, 5000 A Ue = 220, 230, 380, 415, 440, 460, 480, 500, 550, 600, 690 V Ui = 1000 Vac Uimp = 12 kV Icu = 100 kA-500 V, 85 kA-690 V, Ics = 100%Icu Icw = 85 kA, 1 s Rated frequency = 50/60 Hz Cat B		
Trade mark (if any):	LS		
Model/Type reference:	5000 AF: AS-40/50F3- and AS-40/50F4-		
Additional information:	Renewal of certificate NL-13386 dated 2007-10-29 by spot checks. Product compliant with EN 60947-2.		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	2106131.52 (dated 2007-10-29), 2168871.52		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2014-12-09

