

TEST REPORT OF TRIOU

Report No.	QS472-14070410	Date of Manufacture	Jul-14
Date of test	2014. 7.4	Date of issue	2014. 7.4
Item Code	72313460370		
Description	TOTAL ASS`Y,TRIOU,NM		
Applied Standard	The Company Standard		
Rated Voltage	AC/DC 110/220V		
Tested by	Seon-Yong, Jung <i>26 H 13</i>		

Test results

No.	Items of test	Test standard	Test Results
1	Visual and construction inspection	Shall be no defects - Omission of part - Erased marking - Damaged and burned part	Good
2	Soldering test	Shall be no defects - Miss soldering - Circuit Short - Pin hole	Good
3	Operation test	Status LED : DI, DO, CB ON/OFF, RUN, ERROR	Good
Judgement		Pass	

TEST REPORT OF TRIOU

Report No.	QS472-14070411	Date of Manufacture	Jul-14
Date of test	2014. 7.4	Date of issue	2014. 7.4
Item Code	72313460371		
Description	TOTAL ASS'Y,TRIOU,NP		
Applied Standard	The Company Standard		
Rated Voltage	AC/DC 110/220V		
Tested by	Seon-Yong, Jung <i>26 H 13</i>		

Test results

No.	Items of test	Test standard	Test Results
1	Visual and construction inspection	Shall be no defects - Omission of part - Erased marking - Damaged and burned part	Good
2	Soldering test	Shall be no defects - Miss soldering - Circuit Short - Pin hole	Good
3	Operation test	Status LED : DI, DO, CB ON/OFF, RUN, ERROR	Good
Judgement		Pass	

TEST REPORT OF TRIOU

Report No.	QS472-14070412	Date of Manufacture	Jul-14
Date of test	2014. 7.4	Date of issue	2014. 7.4
Item Code	72313460372		
Description	TOTAL ASS'Y, TRIOU, TM		
Applied Standard	The Company Standard		
Rated Voltage	AC/DC 110/220V		
Tested by	Seon-Yong, Jung <i>SY Jung</i>		

Test results

No.	Items of test	Test standard	Test Results
1	Visual and construction inspection	Shall be no defects - Omission of part - Erased marking - Damaged and burned part	Good
2	Soldering test	Shall be no defects - Miss soldering - Circuit Short - Pin hole	Good
3	Operation test	Status LED : DI, DO, CB ON/OFF, RUN, ERROR	Good
Judgement		Pass	

TEST REPORT OF TRIOU

Report No.	QS472-14070413	Date of Manufacture	Jul-14
Date of test	2014. 7.4	Date of issue	2014. 7.4
Item Code	72313460373		
Description	TOTAL ASS`Y,TRIOU,TP		
Applied Standard	The Company Standard		
Rated Voltage	AC/DC 110/220V		
Tested by	Seon-Yong, Jung <i>2014.7.4</i>		

Test results

No.	Items of test	Test standard	Test Results
1	Visual and construction inspection	Shall be no defects - Omission of part - Erased marking - Damaged and burned part	Good
2	Soldering test	Shall be no defects - Miss soldering - Circuit Short - Pin hole	Good
3	Operation test	Status LED : DI, DO, CB ON/OFF, RUN, ERROR	Good
Judgement		Pass	