



CB TEST CERTIFICATE

Ref. Certificate No.

NL-33684

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Air circuit-breaker		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3 and 4 pole ACB (Electronic trip unit) $I_n = 4000\text{ A}, 5000\text{ A}, 6300\text{ A}$ $U_e = 220, 230, 380, 415, 440, 460, 480, 500, 550, 600, 690\text{ V}$ $U_i = 1000\text{ Vac}$ $U_{imp} = 12\text{ kV}$ $I_{cu} = \text{AS type: } 120\text{ kA-500 V}, 100\text{ kA-690 V}$ $\text{AH type: } 150\text{ kA-500 V}, 100\text{ kA-690 V}$ $I_{cs} = 100\%I_{cu}$ $I_{cw} = 100\text{ kA}, 1\text{ s}$ Rated frequency = 50/60 Hz Cat B		
Trade mark (if any):	LS		
Model/Type reference:	6300 AF: AS-40/50/63G3-, AS-40/50/63G4-, AH-40/50/63G3-, AH-40/50/63G4-		
Additional information:	Renewal of certificate NL-13387, dated 2007-10-29, by spot checks. Product compliant with EN 60947-2.		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	2106131.53 (dated 2007-10-29), 2168871.53		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Signed by: F.S.Strikwerda

Date of issue: 2014-12-09